

ORDINANCE NO. 4401

AN ORDINANCE relating to fire hydrants and water mains in the unincorporated areas of King County, modifying fire flow criteria; amending Ordinance #3660, Sect. 13; Ordinance #3087, Section 7; and KCC 17.08.060.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. Ordinance No. 3660, Section 13, Ordinance No. 3087, Section 7, and KCC 17.08.060 are each amended to read as follows: Fire flow criteria. Required fire flows determined by the Fire Marshal shall be based on criteria set forth in the Guide for Determination of Required Fire Flow, 1974 edition, published by the Insurance Service Office. Such required fire flow shall be for a minimum of two hours of continuous flow, except that ~~((this-requirement))~~ the minimum fire flow duration required for Class 2, 3, or 4 water systems serving single-family residential development shall be as shown below:

Residences:

3 to 10	1/2 hour
11 to 50	1 hour
51 to 75	1-1/2 hour
Over 75	2 hours

These requirements shall not apply to those projects which ~~((have-previously))~~ received letters of Fire Marshal approval for

790723-15

Bulletin Board

1 the adequacy of ((water-or)) fire flow and water supply ((in  
2 regards-to-fire-flow-from-the-King-County-Fire-Marshat-as-of-the  
3 effective-date-of-this-ordinance)) prior to April 5, 1978.

4 INTRODUCED AND READ for the first time this 14<sup>th</sup>  
5 day of May, 1979.

6 PASSED this 23<sup>rd</sup> day of July, 1979.

7 KING COUNTY COUNCIL  
8 KING COUNTY, WASHINGTON

9 Ruby Chow  
10 Chairman

11 ATTEST:

12 John Hammond  
13 Clerk of the Council

14 APPROVED this 26<sup>th</sup> day of July, 1979.

15 [Signature]  
16 King County Executive

17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
790723-15