		GARY	CDAN
Introduced	by:	- Control (1)	GIVAIA

Proposed No. 81-374

ORDINANCE NO.

AN ORDINANCE approving the Water Comprehensive Plan for Y Bar S Water System.

## PREAMBLE:

On July 25, 1980, the Y Bar S Water System Comprehensive Plan was submitted for review by the Utilities Technical Review Committee, as required by KCC Chapter 13.24.

On August 13, 1980, the Committee recommended its approval after having made the following findings:

- The existing Y Bar S Water System consists of the combined individual water systems for the approved plats of Y Bar S Ranchettes and Highview Estates.
- 2. The system cannot meet the current fire flow requirements without an intensive upgrading of the transmission lines and storage facilities and the drilling of an additional well.
- 3. The Fire Marshal has determined that the fire flow standards contained in Recommendation No. 1, found on page 7 on the proposed plan, will provide a reasonable degree of fire protection and are acceptable.

In September 1980, the Prosecuting Attorney's Office advised the Committee that the fire flow standards of the King County Code were not subject to waiver.

On april 3, 1981, a proposal was submitted to the Committee whereby a connection to the Krain Water Company would satisfy the fire flow requirements of the Code.

On May 14, 1981, the Committee again recommended that the Plan be approved.

On September 18, 1980, King County filed a Decla-ration of Non-Significance for the approval of the Y Bar S Water System Comprehensive Plan. BE IT ORDAINED BY THE COUNCIL OF KING COUNTY: SECTION 1. The Y Bar S Water System Comprehensive Plan, dated June 1980, and amended on April 3, 1981, is hereby approved; PROVIDED that improvements to the system shall be limited to those specified in Recommendation No. 1. INTRODUCED AND READ for the first time this 8 th day of \_\_\_, 19<u>81</u>. PASSED this 15 Thday of June KING COUNTY COUNCIL KING COUNTY, WASHINGTON ATTEST:

APPROVED this 26th day of June

