February 7, 1985 5852A/BB:vv

INTRODUCE	D BY:	RUBY	CHOW	
PROPOSED	NO.:	84	l-781	

ordinance no._7136

AN ORDINANCE regulating the lead content in plumbing solder repealing Ordinance 6746, Section 38 and K.C.C 16.32.360 and adding new sections to K.C.C. 16.32.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

NEW SECTION. SECTION 1. There is added to K.C.C. 16.32 a new section to read as follows:

Section 802. Subsection (d) of Section 802, Solder and Sweat Joints, of the Uniform Plumbing Code is amended to read as follows:

(d) Joints in copper tubing shall be made by the appropriate use of approved brass or copper fittings. Surfaces to be joined by soldering shall be cleaned bright by manual or mechanical means. The joints shall be properly fluxed with an approved non-corrosive type flux and made up with approved solder. All solder and fluxes shall be manufactured to approved standards. Solder used to join potable water copper tubing shall meet ASTM specification B 32-76 and shall have a maximum lead content of no more than 0.20%.

SECTION 2. Ordinance 6746, Section 38 and K.C.C. 16.32.360 are repealed and the following is substituted:

Section 803. Section 803, Use of Joints, of the Uniform Plumbing Code is amended by:

A. Amending subsection (e), Copper Water Tube, to read as follows: