

September 1, 1988  
0147F/HK:lt

INTRODUCED BY: Lois North

PROPOSED NO.: 88-676

**8726**

ORDINANCE NO. \_\_\_\_\_

AN ORDINANCE adding requirements to the 1985  
Uniform Fire Code relating to the outdoor storage  
of flammable liquids.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. A new section is added to Ordinance 8184 and  
K.C.C. 17.04.

A new subsection is added to Section 79.403 of the Uniform  
Fire Code as follows:

Outdoor storage of flammable liquids in excess of ten gallons  
is not permitted on property used for R-1 and R-3 occupancies.

INTRODUCED AND READ for the first time this 12th day  
of September, 1988.

PASSED this 7th day of November, 1988.

KING COUNTY COUNCIL  
KING COUNTY, WASHINGTON

Bill Reams  
VICE Chair

ATTEST:

Juanita M. Owens  
Clerk of the Council

APPROVED this 15th day of November, 1988.

Don Hill  
King County Executive

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33