

ALARM SYSTEM

Council District: No. 5
CIP Planning Area: Seattle

Youth Services Center Fire Alarm System by the Seattle Fire Department. The following general improvements must be accomplished to comply with Fire Code Ordinance No. 106107.

pull stations in all monitoring cages that presently have none and are not accessible to people in detention.

Smoke detection in corridors and exitways with heat detection in boiler rooms, laundry rooms, handicraft rooms, shop and throughout the building complex.

Alarm System specifications will be submitted to the City of Seattle for final approval prior to commencement of this project.

Changes To Be Abandoned To Be Merged Total Cost Change Site Change
 Revenue Change Scope Change Schedule Change

Status:

\$74,550

Study of Fire Alarm System requirements for the Youth Services Center has been completed.



EXPENDITURES		1978	EXP + BUDGET	*PROGRAM PROJECTIONS - THOUSANDS OF DOLLARS*					OPT/ACCOUNT	
TO 12-31-77	EXISTING	BUDGET RECOMMENDED	+ RECOMMENDED	1979	1980	1981	1982	1983	PROGRAM TOTAL	TOTAL
(A)	(B)	(C)	(A+B+C)							
3350	YOUTH SRVS FACILTS CONST.									
	JUVENILE SERVICES - 335 CIP									
	JUDICIAL									
	FACILITIES									
	REMODELING & RENOVATION									
		4,130	4,130	*	*	*	*	*	*	4,130
		58,918	58,918	*	*	*	*	*	*	58,918
		10,757	10,757	*	*	*	*	*	*	10,757
		745	745	*	*	*	*	*	*	745
		74,550	74,550	*	*	*	*	*	*	74,550
	SHARED REV	74,550	74,550	*	*	*	*	*	*	74,550
		74,550	74,550	*	*	*	*	*	*	74,550
74,550	REVENUE PENDING	0								0

endent Wing Elect./Mech.

Council District: No. 5
 CIP Planning Area: Seattle


ing mechanical and electrical
 wing.

- anges To Be Abandoned To Be Merged Total Cost Change Site Change
 Revenue Change Scope Change Schedule Change

\$71,000

Status:

Defer project indefinitely. Transfer existing budget to a higher priority project involving the installation of a new "Fire Alarm System".



REVISED OCTOBER 1978

