

August 30, 1979

Introduced by: PAUL BARDEN

Proposed No. 79-1169

ORDINANCE NO. 4527

AN ORDINANCE amending the King County Sewerage General Plan adopted by Ordinance No. 4035, providing for increased capacity and secondary treatment at Lakehaven Sewer District's Lakota and Redondo Sewage Treatment Plants.

PREAMBLE:

The Lakehaven Sewer District Comprehensive Plan approved by the King County Council by Ordinance No. 3484 provides for an average design flow 3.22 million gallons per day at the Redondo Treatment Plant and 10,57 million gallons per day at the Lakota Treatment Plant, both with secondary levels of treatment.

As required by RCW 36.94, the King County Sewerage General Plan Review Committee evaluated these proposed capacities and levels of treatment, and on July 11, 1979, recommended their inclusion in the Sewerage General Plan.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. The capacities and level of treatment for the Lakota and Redondo Sewage Treatment Plants as shown in the King County Sewerage General Plan, Page 6, Table 1, are hereby amended as follows:

<u>Facility</u>	<u>Average Dry Weather Flow</u>	<u>Maximum Wet Weather Flow</u>	<u>Level of Treatment</u>
6. Lakota	10.57	50.00	Secondary
9. Redondo	3.22	35.9	Secondary

INTRODUCED AND READ for the first time this 17th day of

September, 1979.

PASSED this 15th day of October, 1979.

KING COUNTY COUNCIL
KING COUNTY, WASHINGTON

Ruby Chow
Chairman

ATTEST:

Jessie M. Alvord

DEPUTY Clerk of the Council

APPROVED this 17th day of October, 1979.

[Signature]
King County Executive