

September 21, 1979

Introduced by: BILL REAMS

Proposed No. 79-1270

ORDINANCE NO. 4543

AN ORDINANCE approving the Grotto Water System Plan.

PREAMBLE:

As required by KCC 13.24, the Utilities Technical Review Committee reviewed the proposed plan and on August 22, 1979 recommended conditional approval of the Grotto Water System Plan.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. The Grotto Water System Plan (attached) is hereby approved, PROVIDED:

A. The number of service connections shall be limited to 33 if a 20,000 gallon storage tank is installed, or

B. The number of service connections shall be limited to 55 if a 30,000 gallon storage tank is installed.

INTRODUCED AND READ for the first time this 15th day of October, 1979.

PASSED this 2nd day of October, 1979.

KING COUNTY COUNCIL
KING COUNTY, WASHINGTON

Ruby Chow
Chairman

ATTEST:

Janet M. Reams

DEPUTY Clerk of the Council

APPROVED this 30th day of October, 1979.

[Signature]
King County Executive