

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33

ORDINANCE NO. 5774

AN ORDINANCE approving Northeast Lake Washington Sewer and Water District Sewer Plan Amendment removing lift stations 5, 6, 8, 11 and 13 (Resolution No. 1981-8-23).

PREAMBLE:

On August 31, 1981, Northeast Lake Washington Sewer and Water District adopted Resolution No. 1981-8-23, which provides for Amendment removing lift stations 5, 6, 8, 11 and 13 (Resolution No. 1981-8-23) to the district's comprehensive plan.

On September 18, 1981, Northeast Lake Washington filed a proposed Declaration of Non-Significance stating that the proposal would not have a significant adverse impact upon the environment.

On September 16, 1981, the proposed Amendment removing lift stations 5, 6, 8, 11 and 13 (Resolution No. 1981-8-23) was submitted to the Utilities Technical Review Committee for review, as required by KCC Chapter 13.24. On October 14, 1981, the Committee recommended its approval, provided:

- 1) The proposed gravity line from Lift Station No. 13 to NE 128th Street is to be located to minimize disruption of the wooded wetland between NE 124th and NE 128th Streets. Preferred routes would include skirting the perimeter of the wetland either on the south or north sides and crossing the Juanita Creek Tributary at a place where the channel is narrow and well defined,
- 2) The district shall obtain and adhere strictly to the conditions of a Fisheries/Game Department Hydraulic Permit Application, and
- 3) Disturbed ground is to be revegetated with "native species" (See attachment for definition of "native species") appropriate for wet situations immediately after construction is completed.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. The proposed Amendment removing lift stations 5, 6, 8, 11, and 13 to the Northeast Lake

Washington Sewer and Water District Comprehensive "Sewer Plan", as adopted by district Resolution No. 1981-8-23 (attached) is hereby approved, provided:

1 A. The proposed gravity line from Lift Station 13 to NE 128th
2 Street is to be located to minimize disruption of the wooded
3 wetland between NE 124th and NE 128th Streets. Preferred routes
4 would include skirting the perimeter of the wetland either on the
5 south or north sides and crossing the Juanita Creek Tributary at
6 a place where the channel is narrow and well defined.

7 B. The district shall obtain and adhere strictly to the
8 conditions of a Fisheries/Game Department Hydraulic Permit
9 Application.

10 C. Disturbed ground is to be revegetated with "native
11 species" (See attachment for definition of "native species")
12 appropriate for wet situations immediately after construction is
13 completed.

14 D. That during construction Juanita Creek should be
15 temporarily culverted across the construction trench.

16 E. Excavation work should be performed in such a manner
17 as to assure that potential storage of the wetland is not
18 permanently lowered by lowering of the outlet level.

19 F. Construction access should be undertaken from the south
20 side of the east-west trench.

21
22
23
24
25
26
27
28
29
30
31
32
33

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33

G. To avoid excessive discharge of silty water, all reasonable efforts should be undertaken to discharge any water pumped from the construction trench to a settling area away from the Creek and wetland.

INTRODUCED AND READ for the first time this 30th day of November, 19 81.

PASSED this 7th day of December, 19 81.

KING COUNTY COUNCIL
KING COUNTY, WASHINGTON

Paul Barden
Chairman

ATTEST:

Dorothy M. Owens
DEPUTY Clerk of the Council

APPROVED this 17th day of December, 19 81.

Randy Lewde
King County Executive