

August 29, 1983

Introduced by: BRUCE LAING

Proposed No. 83 - 498

ORDINANCE NO. 6564

AN ORDINANCE conditionally approving the Overdale Water Association Comprehensive Plan.

PREAMBLE:

As required by KCC 13.24, the Overdale Water Association submitted its Comprehensive Plan to the Utilities Technical Review Committee (UTRC) on February 24, 1983.

After meeting to discuss the Overdale Plan four times, the UTRC, on August 10, 1983, recommended conditional approval of the Overdale Water Plan after making the following findings:

1. The Overdale water source (a well) may be susceptible to contamination caused by the Reid Gravel Pit.
2. The water system is dependent on a two stage pumping system which has no back-up power supply or pumping capacity.
3. The system has only 37,000 gallons of storage. Using Department of Social and Health Services standards, 127,200 gallons of storage is required to serve the 159 lots in Overdale Park.
4. The structural integrity of the Overdale water tank is unknown.
5. The Overdale Water Plan proposes a five part program to address the above referenced problems.

6. Additional connections to the Overdale Water System should not be permitted until the system's problems are corrected.


BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. The Overdale Water Association Comprehensive Plan, as amended by the Association of July 26, 1983, is hereby approved; provided that additional connections to the Overdale System shall not be permitted until the system's deficiencies are corrected.


INTRODUCED AND READ for the first time this 3rd day of October, 1983.

PASSED this 17th day of October, 1983.


KING COUNTY COUNCIL
KING COUNTY, WASHINGTON


Chairman

ATTEST:


Clerk of the Council

APPROVED this 24th day of October, 1983.


King County Executive