

June 27, 1986

INTRODUCED BY: PAUL BARDEN

PROPOSED NO.: 86-393

ORDINANCE NO. 7734

AN ORDINANCE approving the Burton Water Company 1986 Comprehensive Water Plan.

PREAMBLE:

On June 18, 1979, the King County council passed Ordinance 4332, approving the Burton Water Company 1986 Comprehensive Water Plan, with conditions.

On May 9, 1986, the Burton Water Company submitted their 1986 Comprehensive Water Plan to the Utilities Technical Review Committee.

On May 20, 1986, the Utilities Technical Review Committee met and recommended approval based on the following, findings:

1. Fire regulations require eight inches water mains if they are dead-ended, and
2. Department of Social and Health Services district engineer, Moe Batra, requested that source metering be recommended.

On June 17, 1986, King County issued a declaration of non-significance for the Burton Water Company 1986 Comprehensive Water Plan.

BE IT ORDAINED BY THE COUNCIL OF KING COUNTY:

SECTION 1. The Burton Water Company 1986 Comprehensive Water Plan is hereby approved with the following conditions:

A. Projects Two, Three and Four be eight inches if they are dead-ended;

1 B. All dead-end lines over fifty feet shall be eight  
2 inches. The Fire Marshal's Office may modify this provision in  
3 writing; and

4 C. The Burton Water Company's wells should be metered.

5 INTRODUCED AND READ for the first time this 21st day of  
6 July, 1986.

7 PASSED this 25th day of August, 1986.

8 KING COUNTY COUNCIL  
9 KING COUNTY, WASHINGTON

10 Audrey Linger  
11 Chair

12 ATTEST:

13  
14 Janithy M. Owens  
15 Clerk of the Council

16 APPROVED this 4th day of September, 1986.

17 Jim Hill  
18 King County Executive

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33